



**NOTE:**  
 IF KALWALL EV SYSTEM IS TO BE SET BACK FROM OUTSIDE FACE OF ROUGH OPENING, A MINIMUM 19mm STANDOFF IS REQUIRED.

**NOTE:**  
 MINIMUM PANEL AREA 24 Sq Ft (2.2 Sq Meters)

**NOTE:**  
 MINIMUM EV RELEASE PRESSURE MUST BE DESIGN WIND LOAD PLUS 10 PSF (480Pa)

- \* DENOTES CONTINUOUS SUPPORT STRUCTURE NOT BY KALWALL INSTALLER
- (\*) DENOTES ADJUSTMENT SHIMS TO BE SUPPLIED BY KALWALL INSTALLER TO ACCOMMODATE SECONDARY STEEL TOLERANCES, ENGINEER TO ADVISE TOLERANCES.

**EXPLOSION VENTING JAMB & VERTICAL BATTEN  
 KALWALL THERMALLY BROKEN WALL PANEL DETAILS**

Stokes Systems Ltd. 1, Baneland road, Purley, Surrey. CR8 3EB  
 Tel: 020 8660 7067 Fax: 020 8660 5707 Email: design@stokes.co.uk

This drawing is copyright and may not be reproduced in whole or in part without written consent of Stokes Systems Limited.

**STOKES**  
 STOKES SYSTEMS LTD

Detail Ref.		<b>08T-STD/19</b>	
Date.	June 2008	Rev.	-
System.	08T	Scale.	1=2